

<b>Test Code Sheet Number</b>	<b>2</b>	<b>2</b>	<b>1</b>	<b>3</b>	<b>10</b>
---------------------------------------	----------	----------	----------	----------	-----------

TEST CODE SHEET

---

1. **TYPE OF TEST(S)**

Visual inspection - check valve operation.

2. **WATER REGULATIONS REQUIREMENTS FOR FITTINGS**

Schedule 2

15-(1) .... every water system shall contain an adequate device or devices for preventing backflow of fluid from any appliance, fitting or process from occurring.

3. **BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY WATER REGULATIONS REQUIREMENTS**

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of regulations are listed in the directory.

4. **TEST PROCEDURE**

4.1 Tests applicable to the following:-

**NON-VERIFIABLE DISCONNECTOR CA**  
DN6 to DN50.

Devices for the prevention of contamination by backflow.

---

(A) **NON VERIFIABLE DISCONNECTOR CA** (Derived from ASSE 1013 : 1993. Clause 3.5)  
DN6 to DN50.

**TEST METHOD**

**APPARATUS**

Visual examination with the naked eye..

**PROCEDURE** The procedure shall be as follows:-

(1) Visually examine the movement of the first and second check valves through the full limit of their travel.

5. **ACCEPTANCE CRITERIA**

The operation of each individual check valve through its full range of travel shall not bring about any physical contact between the two check valve components.