

Test Code Sheet Number	5	0	3	1	2
---------------------------------------	----------	----------	----------	----------	----------

WBS TEST & ACCEPTANCE CRITERIA
PD.JCS

Issue No: 3
Date of issue: September 1993

Sheet 1 of 1

TEST CODE SHEET

1. **TYPE OF TEST(S)**

Dimension - capacity.

2. **BYELAW REQUIREMENT FOR FITTINGS**

There are no byelaw requirements for capacities of cisterns and tanks, but where the Water Supply Byelaws Guide comments that specific British Standards for such fittings meet other byelaw requirements, it follows that if such British Standards specify capacities then they form part of byelaw compliance.

3. **BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY BYELAW REQUIREMENTS**

(See Water Supply Byelaw Guide)

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of byelaws are listed in the directory.

4. **TEST PROCEDURE**

4.1 Tests applicable to the following fittings-

CYLINDERS - all types.

(A) **BS CYLINDERS**

TEST METHOD

The capacity of the cylinder shall be established by the method specified in the appropriate British Standard, and shall be recorded.

5. **ACCEPTANCE CRITERIA**

The capacity established shall be the same as that required by the appropriate British Standard, within the tolerances specified. The cylinder shall be marked in accordance with the requirements of the British Standards.

(B) **NON-BS CYLINDERS**

TEST METHOD

The cylinder shall be filled with a measured volume of water and the capacity established and recorded.

5. **ACCEPTANCE CRITERIA**

The capacity established shall be the same as that claimed by the manufacturer, within the tolerances specified. The cylinder shall be marked to indicate the capacity in accordance with Test Code Sheet 6001.1.